

Testing method	CRITERIA CLASS B			
	CRITERIA CLASS B	Nº OF TESTS	AVERAGE	COMPLIANCE
UNE-EN-ISO 11925-2:2002	$F_s \leq 150$ mm dentro de 60 s	12	$F_s < 150$ mm	YES
UNE-EN 13823 :2002	$FIGRA_{0.2MJ} \leq 120$ W/s	3	0.00	YES
	LFS < sample edge	3	< to edge	YES
	$THR_{600s} \leq 7.5$ MJ	3	0.46	YES
	CRITERIA subclass 's1'	Nº OF TESTS	AVERAGE	COMPLIANCE
	$SMOGRA \leq 30$ m <sup>2</sup> /s <sup>2</sup>	3	2.55	YES
	$TSP_{600s} \leq 50$ m <sup>2</sup>	3	25.56	YES
	CRITERIA subclass 'd0'	Nº OF TESTS	AVERAGE	COMPLIANCE
	Fall of droplets/particles in flames within 600 s	3	NO	YES